



CERTIFICATE OF CONFORMITY

This is to certify that
HYDRAPANEL



Product description

Hydrapanel wall and ceiling panels are a magnesium oxide board, laminated face and back with High Pressure Laminate as a sandwich construction.

The panels are pre-finished with high pressure smooth decorative laminate or tile textured face supplied as a 3000 or 2400mm x 1200mm having a nominal thickness of 7.6mm.

Product purpose or use

Hydrapanel is a non-structural wall and ceiling lining material, intended for use primarily in wet areas such as bathrooms and kitchens, and in food preparation areas. Hydrapanel may be installed on timber or steel framing, or over existing sheet linings. Hydrapanel can be installed with either proprietary aluminium track or flush fit jointer systems

Certificate holder

Hydrawood Holdings Limited
PO Box 47-927, Ponsonby, Auckland 1144,
New Zealand
p +649 365 1660 f + 649 365 1680
www.hydrawood.co.nz

CodeMark certification body

SAI Global Certification Services Pty Limited
(ACN 108 716 669) Trading as "SAI Global"
JAS-ANZ Accreditation No. Z1440295AS
Address 680 George Street, Sydney, NSW 2000
Website: www.saiglobal.com

Complies with the New Zealand Building Code (NZBC):

if designed, used, installed and maintained in accordance with the scope of this Certificate, the above mentioned product will meet the following provisions of the NZBC:

B1 Structure — B1.3.1 and B1.3.2 for the physical conditions B1.3.3 (a) and (j); B1.3.4(d)

B2 Durability — B2.3.1(b)

C3 Fire Affecting Areas Beyond the Source — C3.4(a)

E3 Internal Moisture — E3.3.4, E3.3.5, E3.3.6

F2 Hazardous Building Materials — F2.3.1

G3 Food Preparation and Prevention of Contamination — G3.3.2

Subject to the following conditions and limitations:

1. When used as a splashback behind a cooktop the following minimum distances must be maintained:
 - a. electric cook top – 100mm from the outer ring of the nearest heating element;
 - b. gas cook top – 200mm from the closest outer ring of the hob
2. The installation must be in accordance with the manufacturer's instructions: Hydrapanel Specification and Installation Guide v4.4 May 2018. The components are detailed in the installation manual.

Kevin Goodwin
General Manager Technical
Services

SAI Global Assurance

3/09/2018

Date of issue

CM20090

Certificate Number

**BUILDING
PERFORMANCE**

MINISTRY OF BUSINESS,
INNOVATION & EMPLOYMENT
HIKINA WHAKATUTUKI

JAS-ANZ



WWW.JAS-ANZ.ORG/REGISTER

This certificate is issued by SAI Global Certification Services Pty Limited, an independent certification body accredited by the product certification accreditation body (JAS-ANZ) appointed by the Chief Executive of the Ministry of Business Innovation & Employment (MBIE) under the Building Act 2004. The MBIE does not in any way warrant, guarantee, or represent that the building method or product the subject of this certificate conforms with the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. The MBIE disclaims, to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages, and costs arising as a result of the use of the building method(s) or product(s) referred to in this certificate. The certificate holder must maintain compliance with the conditions set out in section 15 of the Building (Product Certification) Regulations 2008. This Certificate may only be reproduced in its entirety