

## HYDRAPANEL LINING PANEL

### PURPOSE

The Hydrapanel lining panel (the panel) is supplied by Hydrawood Flooring Systems Ltd for use as a non-structural, internal wall or ceiling lining in wet or dry areas.

### EXPLANATION

The panels are 7.6 mm thick, laminated on the outer faces in a sandwich construction with a decorative high-pressure laminate. The core is magnesium oxide. The outer faces are abrasion-resistant, easily cleaned and maintained, and impervious to moisture and steam. The panels also have fire-resistant properties and when tested to EN 13501 achieves an A1 category.

The following panel sizes are available:

- Flushfit – 2400 mm x 1200 mm and 3000 mm x 1200 mm
- Subway Tile – 2400 mm x 1200 mm, with a 300 mm x 100 mm pattern
- Tile – 2400 mm x 1200 mm, with a 600 mm x 300 mm pattern.

The panel can be installed with a proprietary aluminium track or a Flushfit jointer system. They can also be bonded to timber, lightweight steel, masonry, concrete and engineered panel substrates provided the substrates are clean, dry and free of contaminants.



For further assistance please contact:

- ☎ +64 9 3651660
- ✉ info@hydrawood.co.nz
- 🌐 www.hydrapanel.co.nz



### SCOPE AND LIMITATIONS OF USE

Scope	Limitations
<b>Building</b>	
In all buildings where the relevant structure complies with the NZ Building Code or, for existing buildings, where the designer and the installer have satisfied themselves that the existing structure is suitable for the intended building work.	
On timber or lightweight steel framing, and masonry, concrete and engineered panel substrates.	<ul style="list-style-type: none"> <li>➤ The substrates must be clean, dry and free from contaminants including dust.</li> <li>➤ The panels must be installed to concrete walls using timber battens with a DPC installed between the timber and concrete surface.</li> </ul>
As a wall lining (vertical or horizontal).	<ul style="list-style-type: none"> <li>➤ Studs or nogs must be at a maximum of 600 mm centres.</li> </ul>
As a ceiling lining.	<ul style="list-style-type: none"> <li>➤ Battens must be at a maximum of 400 mm centres.</li> </ul>
In buildings of any use.	<ul style="list-style-type: none"> <li>➤ Where a material group number 2 or greater is permitted.</li> </ul>



### USEFUL INFORMATION

For information on the design, installation and maintenance of the Hydrapanel lining panel and for our warranty refer to [www.hydrapanel.co.nz](http://www.hydrapanel.co.nz).

### VERSION:

## PERFORMANCE CLAIMS

If designed, installed and maintained in accordance with all Hydrawood Flooring Systems Ltd requirements, the Hydrapanel lining panel will comply with or contribute to compliance with the following performance claims: G3.3.2 (a)n/a

NZ Building Code clauses	BASIS OF COMPLIANCE <sup>1</sup>	
	Compliance statement	Demonstrated by
<b>B1 Structure</b> B1.3.1, B1.3.2, B1.3.3 (a, b, e, j) B1.3.4 (a, b, c, d, e)	ALTERNATIVE SOLUTION	<ul style="list-style-type: none"> <li>▶ The University of Auckland. AS/NZS 2908.2. [03/09/2012].</li> <li>▶ Hydrawood Holdings Limited. Technical specification. [02/09/2019].</li> </ul>
<b>B2 Durability</b> B2.3.1 (b), B2.3.2 (b)	ALTERNATIVE SOLUTION	<ul style="list-style-type: none"> <li>▶ Hydrawood Holdings Limited. Technical specification. [02/09/2019].</li> <li>▶ The University of Auckland. AS/NZS 2908.2. [14/09/2012].</li> </ul>
<b>C3 Fire Affecting Areas Beyond the Fire Source</b> C3.4 (a)	ACCEPTABLE SOLUTION C2/AS1 (1 <sup>st</sup> edition, 2019)	<ul style="list-style-type: none"> <li>▶ SGS. EN 13501-1:2007 + A1:2009, achieves Class A1. [21/01/2016].</li> </ul>
<b>E3 Internal Moisture</b> E3.3.4, E3.3.5, E3.3.6	ACCEPTABLE SOLUTION E3/AS1	<ul style="list-style-type: none"> <li>▶ High Pressure Laminated referenced in para. 3.1.2, E3/AS1.</li> <li>▶ Hydrawood Holdings Limited. Technical specification. [02/09/2019].</li> <li>▶ The University of Auckland. AS/NZS 2908.2. [14/09/2012].</li> </ul>
<b>F2 Hazardous Building Materials</b> F2.3.1	ALTERNATIVE SOLUTION	<ul style="list-style-type: none"> <li>▶ Shandong Yurui International Trade Co. Ltd Material safety data sheet. Magnesium Oxide Board. [n.d.].</li> <li>▶ Shanghai Changyin Testing Technology Co. Ltd. Material safety data sheet. No. A001R161130002. High Pressure Laminate. [01/12/2016].</li> </ul>
<b>G3 Food Preparation and Prevention of contamination</b> G3.3.2 (a)	ACCEPTABLE SOLUTION G3/AS1	<ul style="list-style-type: none"> <li>▶ High Pressure laminate referenced in para. 1.6 of G3/AS1.</li> </ul>

1. The Compliance Statement is the pass holder's statement that they have met their obligations under s14G(2) of the Building Act 2004.

## SOURCES OF INFORMATION<sup>2</sup>

- ▶ Hydrapanel. [5/2018] *Installation and specification guide. Version 4.4.*
  - ▶ Hydrawood Holdings Limited. [2/09/2019] *Quality Plan Summary.*
  - ▶ Ministry of Business, Innovation and Employment. [2015] *Achieving NZBC Group Numbers for surface finishes from tests to overseas standards.*
  - ▶ Shandong Yurui International Trade Co. Ltd. [n.d.] *Material safety data sheet. Magnesium Oxide Board.*
  - ▶ Shanghai Changyin Testing Technology Co. Ltd. [01/12/2016] *Material Safety Data Sheet. No. A001R161130002.*
  - ▶ SGS. [21/01/2016] EN 13501-1:2007 + A1:2009. *Fire classification of construction products and building elements.* Test Report No. SHCCM160100059.
  - ▶ The University of Auckland. [03/09/2012] *Report on Bending Strength Test on the basis of AS/NZS 2908.2. Hydrapanel.* Test Report: 2908.
  - ▶ The University of Auckland. [14/09/2012] *Report on Hydrapanel Water Permeability Test on the basis of AS/NZS 2908.2.* Test Report: 2908A.
2. Sources of information also include the Building Act 2004 and its regulations, including the Building Code (Schedule 1 of the Building Regulations 1992), Acceptable Solutions and Verification Methods, and relevant cited standards.

Scan or click this QR code for a full download of Compliance Documentation for this pass™.  
[www.hydrapanel.co.nz](http://www.hydrapanel.co.nz)



**VERSION:**

.....

Note: Uncontrolled in printed format.

**DATE:**

.....

Signed on behalf of Hydrawood Flooring Systems Ltd:

**NAME:**

.....

**POSITION:**

.....

Brad Smith

Managing Partner

By signing this pass™ the signatory confirms that, in respect of the subject of this pass™, the company has met their s14G obligations under the Building Act 2004.



4 Holdaway Avenue, Northcote, Auckland 0627 > [info@hydrawood.co.nz](mailto:info@hydrawood.co.nz) > +64 9 3651660 > [www.hydrapanel.co.nz](http://www.hydrapanel.co.nz)

This Product Assurance Supplier Statement (pass™) has been prepared by TBB in accordance with MBIE PTS guidelines and the recommendations of s9.2, Determination No. 2019-011 (issued 12 April 2019). TBB is ISO9001:2016 certified. Copyright © 2017, The Building Business Limited (TBB). All rights reserved.